

AAA ELECTRIC INC
5703 Milwaukee Ave E
Puyallup WA 98372
253 -445-1893

April, 10 2009

To: Rainier Commons,
From: Charles Bitton
RE: Transformers

I have been the general electrical contractor for approximately the last five years on the rainier commons project. I have investigated the two large 4160 to 480 volt transformers located in Tully's packing area and building 25. They are both dry type and after some research and investigation it is my professional opinion that there is no PCB's present in these transformers. If you have any questions or concerns please call me on my cell phone at (b) (6)

Sincerely,
Charles Bitton